

UNIVERSITI SAINS MALAYSIA

Peperiksaan Semester Pertama
Sidang Akademik 1992/93

Oktober/November 1992

EMK 404 - Penyejukan dan Penyamanan Udara

Masa : [3 jam]

ARAHAN KEPADA CALON:

Sila pastikan bahawa kertas peperiksaan ini mengandungi TUJUH (7) soalan dan TUJUH (7) muka surat serta EMPAT BELAS (14) lampiran yang bercetak sebelum anda memulakan peperiksaan ini.

Jawab LIMA (5) soalan sahaja.

Semua soalan mestilah dijawab dalam bahasa Malaysia.

Termasuk lampiran-lampiran:

1. Analisis Beban Penyamanan Udara.
2. Jadual: "Recommended NC (Noise Criteria)".

1. [a] Terangkan dengan ringkas pengendalian sebuah kitar penyerapan Ammonia - Air dengan berbantuan sebuah rajah skima.

(30 markah)

- [b] Sebuah loji mampatan wap menggunakan R12 sebagai bahan pendingin. Suhu tepu penyejat adalah -20°C dan suhu tepu pemeluwap adalah 50°C . Proses mampatan adalah isentropi. Dengan menggunakan rajah P-h yang disediakan tentukan kesan penyejukan dan pekali prestasi bagi keadaan-keadaan berikut:

- [i] Kitar Carnot
- [ii] jika wap adalah tepu kering selepas proses mampatan
- [iii] jika wap adalah tepu kering sebelum proses mampatan
- [iv] jika wap adalah tepu kering sebelum proses mampatan dan 10K subsejuk selepas proses pemeluwap.
- [v] Bincangkan perbezaan nilai kesan penyejukan dan pekali prestasi.

(70 markah)


2. Sebuah sistem penyejukan mampatan wap menggunakan susunan yang ditunjuk pada Rajah S2. Sistem tersebut mengandungi 2 peringkat mampatan dengan pengantara sejuk diantara kedua-dua peringkat. Bahan pendingin yang digunakan adalah R12.

Wat tepu pada suhu -30°C memasuki pemampat peringkat pertama. Kebuk kilat dan kebuk campuran dikendalikan pada tekanan 4 bar. Tekanan pemeluwap adalah 12 bar. Cecair tepu memasuki injap pengembangan tekanan tinggi pada 12 bar dan injap pengembangan tekanan rendah pada 4 bar. Kedua-dua proses mampatan adalah isentropi. Muatan penyejukan adalah 10 ton.

Tentukan:

- [a] kuasa masukan pada setiap pemampat dalam kW.
- [b] pekali prestasi
- [c] lakarkan kitar tersebut pada rajah P-h.
- [d] terangkan kenapa sistem di atas mempunyai pekali prestasi yang lebih baik daripada sistem yang mempunyai satu peringkat mampatan.

(100 markah)




Rajah S2

3. [a] Terangkan dengan ringkas sistem penyejukan jet stim berbantuan rajah skima. Nyatakan 2 penggunaan sistem tersebut.

(30 markah)
..4/-

- [b] Kapal terbang menggunakan kitar terbuka terbalik Brayton untuk menyejukan kabin. Di dalam unit ini, sedikit udara dikeluarkan daripada pemampat pada tekanan 4 bar dan suhu 280°C dan disalurkan melalui penukar haba tersebut udara (air cooled heat exchanger) seperti Rajah S3[b].



Rajah S3[b]

Udara tersebut meninggalkan penukar haba pada tekanan 4 bar dan suhu 80°C dan dikembangkan melalui sebuah turbin udara ke tekanan 0.75 bar. Kecekapan turbin udara adalah 88%. Udara kemudiannya dihantar ke kabin pada suhu 16°C .

Tentukan kesan penyejukan per kg udara dan kuasa yang dihasilkan oleh turbin udara per kg udara per saat.

(70 markah)

4. [a] Nyatakan jenis-jenis pemampat yang digunakan di dalam sistem penyejukan.

(10 markah)

..5/-

[b] Bincangkan dengan ringkas 3 ciri bahan pendingin.

(10 markah)

[c] Terangkan sebabnya mengapa bahan pendingin dipanas lampaukan sebelum proses mampatan.

(10 markah)

[d] Sebuah sistem mampatan wap dikendalikan diantara suhu tepsu 40°C dan -10°C . Darjah panas lampau sebelum proses mampatan isentropi adalah 20K. Terdapat 10K darjah subsejuk selepas proses pemeluwapan. Tentukan kesan penyejukan, kerja mampatan dan pekali prestasi bagi bahan pendingin berikut:

[i] R12

[ii] Ammonia


Bincangkan jawapan yang anda perolehi.

(70 markah)

5. [a] Nyatakan 5 faktor yang menyebabkan pertambahan haba deria dan 4 faktor yang menyebabkan pertambahan haba pendam.

(30 markah)

[b] Sebuah pejabat di Universiti Sains Malaysia adalah ditunjukkan pada Rajah S5[b].



Rajah S5[b]

.. 6/-

Data yang dikumpulkan adalah seperti berikut:

- [i] keadaan terekabentuk dalaman 78°F , 50% kelembapan relatif.
- [ii] keadaan terekabentuk luaran 93°F (bebuli kering), 82°F (bebuli basah).
- [iii] Bilangan penghuni 12
- [iv] Tembok: 8 inci (plain hollow concrete wall with no interior facing and no interior finish).
- [v] Tingkap: 'single-strength glass shaded by light colour venetion blinds on the inside wall'
- [vi] Lampu: 70 lampu fluorescent (dipasang selama 8 jam daripada pukul 8.00 pagi sehingga 4.00 petang). Setiap lampu adalah $36\text{W} \times 1.2$ untuk 'ballast'
- [vii] Pengalihudara bagi 12 orang adalah 15 kaki³/min setiap orang
 - [a] Tentukan beban penyejukan dalam Btu/hr dan kW menggunakan jadual dalam lampiran 1.
 - [b] Tentukan bilangan alat penyamanan udara jenis tingkap. Setiap satu alat mempunyai muatan penyejukan 2 ton.

(70 markah)

6. [a] Apakah 6 proses asas di dalam psikrometri? Beri contoh penggunaan setiap proses tersebut.

(30 markah)

- [b] Aliran udara luar dicampur dengan aliran balik udara di dalam sebuah sistem penyamanan udara. Kadar alir udara luar adalah 2 kg/s dan keadaan udara luar adalah 35°C bebuli kering. Kadar alir balik udara adalah 3 kg/s dan keadaannya adalah 24°C bebuli kering dan 50% kelembapan relatif. Garis nisbah bilik adalah 0.72. Udara selepas melalui gelung penyejuk adalah 90% tepu.

Lukiskan proses tersebut di atas Carta psikrometri (lampiran 1).

Tentukan:

- [i] titik embun udara
- [ii] suhu selepas gelung penyejuk
- [iii] kadar penyejukan
- [iv] amaun bendalir terpeluwat setiap jam

(70 markah)

7. [a] Senaraikan komponen utama sebuah sistem pengagihan udara.

(15 markah)

- [b] Terangkan istilah-istilah untuk menerangkan prestasi sebuah sistem pengagihan udara.

(15 markah)

- [c] Terangkan jenis-jenis peranti mencuci udara.

(15 markah)

- [d] Sebuah restoran berukuran 60 kaki x 80 kaki dan memerlukan 15 ton beban penyejukan. Tentukan bilangan penyelerak siling yang diperlukan bagi siling 12 kaki jika perbezaan suhu diantara luar dan dalam adalah 22°F . Rujuk lampiran 2.

(55 markah)

0000000

125

[EMK 404]

LAMPIRAN 1

ANALISIS BEBAN PENYAMANAN UDARA
(ANALYSIS OF THE AIR CONDITIONING LOAD)

$$\begin{aligned}1 \text{ Btu/hr} &= 0.293 \text{ W} \\&= 2.93 \times 10^{-4} \text{ kW} \\&= 7 \times 10^{-5} \text{ kcal/sec}\end{aligned}$$

[1/12]




FIG. 7-20 Psychrometric chart for high temperatures—USCS units.

TABLE 8-1 Recommended Inside Design Conditions,* Summer and Winter—Present Practice and Possible Future Trends

Type of Application	Summer						Winter					
	Present Practice		Future Trends (Energy-Dictated)			Temp. Swing, † °F	Present Practice			Future Trends (Energy-Dictated)		
	Dry Bulb, °F	Rel. Hum., %	Dry Bulb, °F	Rel. Hum., %	Dry Bulb, °F	Rel. Hum., %	Temp. Swing, ‡ °F	Dry Bulb, °F	Rel. Hum., %	Temp. Swing, § °F	Dry Bulb, °F	Temp. Swing, § °F
General comfort												
Apartment, house, hotel, office, hospital, school, etc.	78-80	50	80-82	50	2 to 4	72-74	40-30	-3 to -4	68-70	-4		
Retail shops (short-term customer occupancy)												
Bank, barber or beauty shop, department store, supermarket, etc.	78	50	78-80	50	2 to 4	70-72	40-30§	-3 to -4	68-70	-4		
Low sensible-heat-factor (SHF) applications (high latent load)												
Auditorium, church, bar, restaurant, kitchen, etc.	78	60-50	78-80	60-50	1 to 2	70-72	40-35	-2 to -3	68-70	-4		
Factory comfort												
Assembly areas, machining rooms, etc.	78-80	60-50	80-85	60-50	2 to 4	68-72	35-30	-3 to -5	66-68	-4		

* The room design dry-bulb temperature should be reduced when hot, radiant panels are adjacent to the occupant and increased when cold panels are adjacent, to compensate for the increase or decrease in radiant heat exchange from the body. A hot or cold panel may be unshaded glass or glass block windows (hot in summer, cold in winter) and thin partitions with hot or cold spaces adjacent. An unheated slab floor on the ground or walls below the ground level are cold panels during the winter and frequently during the summer also. Hot tanks, furnaces, or machines are hot panels.

† Temperature swing is above the thermostat setting at peak summer load conditions.

‡ Temperature swing is below the thermostat setting at peak winter load conditions (no lights, people, or solar heat gain).

§ Winter humidification in retail clothing shops is recommended to maintain the quality texture of goods.

Sources: Carrier Air Conditioning Co., *Handbook of Air Conditioning System Design*, McGraw-Hill Book Company, New York, 1966; and current federal, state, and local standards.

TABLE 8-3 Suggested Outside Design Conditions for Selected Localities throughout the World

Place	Summer			Place	Summer		
	Winter, Dry Bulb, °C	Dry Bulb, °C	Wet Bulb, °C		Winter, Dry Bulb, °C	Dry Bulb, °C	Wet Bulb, °C
Athens, Greece	31	34	22	Panama City, Panama	22	33	27
Bogota, Columbia	7	21	16	Paris, France	-6	30	20
Bombay, India	18	34	28	Rio de Janeiro, Brazil	14	33	26
Buenos Aires, Argentina	0	32	24	Riyadh, Saudi Arabia	3	42	25
Cairo, Egypt	7	38	24	Rome, Italy	-1	33	23
Capetown, South Africa	4	32	22	Shanghai, China	5	32	28
Caracas, Venezuela	11	28	21	Singapore	22	33	27
Kuala Lumpur, Malaysia	21	34	28	Stockholm, Sweden	-15	24	17
London, England	-4	27	19	Sydney, Australia	4	29	23
Madrid, Spain	-4	33	21	Tel Aviv, Israel	4	34	23
Manila, Philippines	20	33	27	Tokyo, Japan	-3	32	27
Melbourne, Australia	2	33	21	Vienna, Austria	-14	30	21
Mexico City, Mexico	2	27	16				

ASHRAE Handbook, 1977 Fundamentals.




TABLE 8-4 Conductivities K , Conductances C , and Resistances R of Common Building Materials [Units of K , Btu/(hr)(ft²)(F°)/in.; Units of C , Btu/(hr)(ft²)(F°) for Thickness Stated, Not per Inch Thick; Units of R , (hr)(ft²)(F°)/Btu]

Material	Description	Conductivity K	Conductance C	Resistance R
Building boards	Gypsum board.	1.41		
	0.5 in.		2.22	0.45
	0.625 in.		1.78	0.56
Plywood:		0.81		
	0.5 in.		1.60	0.62
	0.75 in.		1.07	0.93
Wood:				
	Fir or pine sheathing, $\frac{3}{8}$ in.		1.02	0.98
Flooring materials	Asphalt tile, vinyl tile		20.0	0.05
	Carpet with fiber pad		0.48	2.08
	Ceramic tile, 1 in.		12.5	0.08
	Cork tile	0.45		
	Linoleum, $\frac{1}{8}$ in.		12.0	0.083
	Plywood subfloor, 0.75 in.		1.07	0.93
	Terrazzo, 1 in.		12.5	0.08
	Wood, hardwood, $\frac{3}{8}$ in.		1.47	0.68
Glass		5.5		
Insulating materials:				
Blanket and batt	Mineral wool, fiberglass	0.29–0.27		
	3.5 in.		0.091	11
	6 in.		0.045	22
	8–10 in.		0.033	30
Board	Cork	0.34		
	Polyurethane	0.16		
	Wood or cane fiber	0.35		
	Polystyrene	0.20		
	Acoustical tile:			
	0.5 in.		0.80	1.25
	0.75 in.		0.53	1.9
	Interior finish boards:	0.35		
	0.5 in.		0.70	1.43
Loose fill	Mineral wool	0.27		
	4 in.			11
	6 in.			20
	10 in.			28
Masonry materials	Wood pulp	0.30		
	Cement mortar	5.0		
	Stucco	5.0	6.6 for $\frac{3}{8}$ in. thick	0.15
Masonry units	Brick, common, low-density	5.0		
	Brick, high-density (face brick)	9.0		
	Concrete blocks:			
	Sand and gravel aggregate:			
	8 in.		0.90	1.11
	12 in.		0.78	1.3
	Cinder aggregate:			
	8 in.		0.58	1.7
	12 in.		0.53	1.9
Plastering materials	Stone	12.5		
	Gypsum plaster, sand aggregate	5.6		
	Gypsum lath ("button board," 0.5 in.) and plaster, plaster thickness 0.625 in.		1.52	0.66
	Metal lath and plaster, plaster thickness 0.75 in.		2.13	0.47

Material	Description	Conductivity K	Conductance C	Resistance R
Roofing materials	Asphalt roll roofing, 70 lb	6.50	0.15	
	Asphalt shingles, 70 lb	2.27	0.44	
	Built-up roofing, 0.375 in.	3.00	0.33	
	Slate, 0.5 in.	20.00	0.05	
Siding materials	Wood shingles, cedar	1.06	0.94	
	Shingles, wood, 16 in, 7.5 in. to the weather		1.15	0.87
	Siding, redwood, or cedar, lap, average		1.20	0.83
	Board and batt, cedar, 1 in.		0.95	1.05
	Aluminum, applied on 0.375 insulating board		0.55	1.82
Woods	Maple, oak, and similar hardwoods	1.20		
	Fir, pine, and similar softwoods	0.84		
	Plywood, 0.625 in.		1.29	0.77
	California redwood	0.74		

American Society of Heating, Refrigerating, and Air Conditioning Engineers, ASHRAE Handbook, 1977 Fundamentals, and various industry sources.

TABLE 8-5 Coefficients of Heat Transmission U of Selected Frame Walls [in Btu/(hr)(ft²)(F°) Difference between the Air on the Two Sides, Effect of Studding Neglected; Effect of Air Films Included]

Diagram of Wall and Exterior Finish	Interior Finish	Type of Exterior Sheathing and Wall Insulation			
		Plywood 0.5 in. and Building Paper		Insulating Board 2 $\frac{1}{2}$ in.	
		No Insulation	3.5 in. Insulation (R-11) in air space	No Insulation	3.5 in. Insulation (R-11) in air space
Wood siding  Also applicable to: Wood shingles 7-in. exposure Board and batt siding ¾ in. thick	Gypsum board (dry wall) Gypsum lath and plaster Metal lath and plaster Plywood or wood paneling, 0.5 in. Insul. board 0.5 in.	0.25 0.24 0.28 0.35 0.22	0.069 0.067 0.075 0.082 0.064	0.20 0.19 0.24 0.26 0.16	0.062 0.06 0.07 0.075 0.057
Stucco 	Gypsum board (drywall) Gypsum lath and plaster Metal lath and plaster Plywood or wood paneling, 0.5 in.	0.32 0.30 0.36 0.38	0.072 0.070 0.080 0.083	0.22 0.21 0.23 0.22	0.071 0.067 0.073 0.076
Brick veneer 	Gypsum board (drywall) Gypsum lath and plaster Metal lath and plaster Plywood or wood paneling, 0.5 in. Wood lath and plaster	0.30 0.28 0.34 0.34 0.33	0.071 0.070 0.078 0.083 0.083	0.21 0.20 0.22 0.24 0.21	0.068 0.065 0.072 0.07 0.07

Source: ASHRAE Handbook, 1977 Fundamentals, and manufacturers' data.

Lights

For incandescent lamps the value 3.4 Btu/(hr)(W) of installed lamps should be used.

TABLE 8-6 Coefficients of Heat Transmission U of Masonry Walls [in Btu/(hr)(ft²)(F°) Difference between the Air on the Two Sides; Effects of Air Films Included]

Diagram of Wall and Type of Masonry	Thickness of Masonry, in.	Interior Finish and Insulation (If Indicated)			
		Plain Wall, No Interior Finish	Metal Lath and Plaster, Furred	Gypsum Lath and Plaster, Furred	Gypsum Drywall on 1 x 3 Furring Strips with 0.75-in. Rigid Board Insulation
Solid brick	8	0.50	0.32	0.30	0.15
	12	0.35	0.25	0.24	0.14
	16	0.28	0.21	0.20	0.13
Stone	8	0.70	0.39	0.36	0.16
	12	0.57	0.35	0.33	0.15
	16	0.49	0.32	0.30	0.14
Poured concrete	6	0.79	0.42	0.39	0.16
	8	0.70	0.39	0.36	0.15
	12	0.58	0.35	0.33	0.14
Hollow concrete blocks (no exterior facing)	8	0.56	0.34	0.32	0.14
	12	0.50	0.32	0.30	0.13
(with 4-in. face brick exterior or stone facing)	8	0.33	0.26	0.24	0.13
	12	0.31	0.24	0.23	0.12

ASHRAE Handbook, 1977 Fundamentals, and manufacturers' data.

TABLE 8-7 Coefficients of Heat Transmission U of Frame Partitions and Interior Walls [in Btu/(hr)(ft²)(F°) Difference between the Air on the Two Sides]

Diagram of Wall	Double Partition (Finish Both Sides)	
	No Insulation between Studs	3.5 in. Blanket Insulation between Studs (R-11)
Type of interior finish		
Gypsum lath and plaster	0.27	0.082
Metal lath and plaster	0.31	0.095
Plywood or wood paneling (½ in.)	0.33	0.105
Gypsum board (drywall), decorated	0.29	0.085

Source: ASHRAE Handbook, 1977 Fundamentals, and manufacturers' data.






TABLE 8-8 Coefficients of Heat Transmission U of Frame Construction Ceilings and Floors [in Btu/(hr)(ft²)(F°) Difference between the Air on the Two Sides]

Type of Ceiling or Floor	No insulation	6-in mineral wool blanket between joists (R-19)	8-10 in. Blown mineral wool (R-30)
Ceilings (unheated attic space above)			
Plaster on gypsum board, on wood joists	0.63	0.055	0.045
Plaster on metal lath on wood joists	0.74	0.057	0.05
Gypsum board (drywall) decorated	0.75	0.057	0.05
Floors (over crawl space or basement)			
Hardwood on 2½-in. subfloor on wood joists	0.37		
Carpet on fiber pad on ¼-in. plywood subfloor on wood joists	0.24		
Linoleum or asphalt tile on 1-in. plywood subfloor on wood joists	0.57		

Type of ceiling	Hardwood on 2½-in. Subfloor	Carpet on Fiber Pad on ¼-in. Plywood Subfloor	Linoleum or Asphalt Tile on 1-in. Plywood Subfloor	Linoleum or Asphalt Tile on 4-in. Concrete
Plaster on gypsum board on wood joists	0.22	0.17	0.28	
Plaster on metal lath on wood joists	0.25	0.20	0.26	
Gypsum (drywall)	0.23	0.19	0.25	
Plaster on metal lath on furring strips				0.33

ASHRAE Handbook, 1977 Fundamentals, and manufacturers' data.

TABLE 8-9 Coefficients of Heat Transmission U of Typical Flat Roofs Covered with Built-up Roofing [in Btu/(hr)(ft²)(F°)]
Difference between the Air on the Two Sides]

Type of Roof Deck (Ceiling Not Shown)	Thickness of Roof Deck, in.	Type of Suspended Ceiling	Insulation on Top of Deck (Covered with Built-up Roofing), in.		
			None	1	2
Flat metal roof deck 	2	None	0.67	0.23	0.15
		Gypsum bd. and plaster (½ in.)	0.32	0.17	0.12
		Acoustical tile (¾ in.)	0.23	0.14	0.11
Concrete slab (light-weight aggregate) 	4	None	0.30	0.18	0.11
		Gypsum bd. and plaster (½ in.)	0.18	0.12	0.09
		Acoustical tile (¾ in.)	0.15	0.11	0.08
Wood, on 2 x 8 joists 	1	None	0.24	0.11	0.09
		Gypsum bd. and plaster (½ in.)	0.13	0.10	0.08
		Acoustical tile (¾ in.)	0.12	0.09	0.07
Wood, on 2 x 8 joists 	2	None	0.40	0.19	0.15
		Gypsum bd. and plaster (½ in.)	0.24	0.15	0.11
		Acoustical tile (¾ in.)	0.19	0.13	0.10
Wood, on 2 x 8 joists 	3	None	0.28	0.16	0.11
		Gypsum bd. and plaster (½ in.)	0.19	0.13	0.10
		Acoustical tile (¾ in.)	0.16	0.11	0.09

ASHRAE Handbook, 1977 Fundamentals, and manufacturers' data.

TABLE 8-11 Effect of Various Shading Conditions on Solar-Radiation Heat Gain (Multiply the SCs by Solar-Heat-Gain Factors from Table 15)

Type of Shading Device	Shade Coefficients (SC)
Canvas awning	0.25
Inside venetian blinds, set at 45°, light color	0.55
Inside venetian blinds, set at 45°, dark color	0.64
Roller shades, fully drawn, light color	0.25
Roller shades, fully drawn, dark color	0.59
Single glass: regular sheet	1.00
¼-in. plate glass	0.95
½-in. plate glass	0.91
¾-in. plate glass	0.88
Roof overhang or marquee, full shading	0.25
Windows shaded by normal setback from external building surface	0.90
Outside shading screen	0.30
Wood sash (85% gross area equals net glass area)	0.85

ASHRAE handbooks and manufacturers' data.

TABLE 8-12 Coefficients of Heat Transmission U of Vertical Windows (Exterior)

Type of Glass	U, Btu per (hr)(ft ²)(F°)			
	No Indoor Shade	Indoor Shade	Indoor Shade	Indoor Shade
Single-strength glass	1.04	0.81		
Double-strength (single-pane) glass	0.85	0.70		
Extra-heavy plate glass	0.78	0.55		
Double glass, insulating, ¼-in. air space	0.61	0.54		
Triple glass, insulating, ¼-in. air spaces	0.44	0.40		
Storm windows, 1 to 4 in. air space	0.50	0.48		

ASHRAE handbooks and manufacturers' data.

TABLE 8-13 Calculation of Outside-Air Infiltration—
Air-Change Method

H = room height
W = width

L = length
G = wall factor

Room with:

One outside wall, G = 1

Two outside walls, G = 1.5

Three outside walls, G = 2

$$\text{cfm} = \frac{W \times H \times L \times G}{60}$$

Note:

1. For rooms with good weatherstripping on windows and doors, use 50 percent of the value calculated.

2. For commercial establishments where doors are opened frequently, add 100 ft³ per person per passage for each 36-in. swinging door.

3. Vestibules—reduce by 25 percent, revolving doors by 75 percent.

4. Residences—three-quarters air change per hour.

Source: Reprinted by permission of the Air Conditioning and Refrigeration Institute, Arlington, Va.

Infiltration

$$H_s = \text{cfm} \times 1.08 \times (L - 4)$$

(sensible heat gain from outside air)

$$H_L = \text{cfm} \times 0.68 \times (W_o - W_r)$$

(latent heat gain from outside air)

TABLE 8-14 Infiltration through Cracks (Cubic Feet per Minute per Lineal Foot of Crack)

Type of Window or Door	Remarks	Wind Velocity, mi/hr		
		5	10	30
Double-hung wood sash	Average window in wood frame, non-weatherstripped	0.12	0.65	1.73
	Same, weatherstripped	0.07	0.40	1.05
	Poorly fitted window in wood frame, non-weatherstripped	0.45	1.85	4.20
Steel sash, rolled section	Same, weatherstripped	0.10	1.57	1.53
	Architectural, projected	0.25	1.03	2.30
	Industrial, pivoted	0.87	2.90	6.20
	Residential casement	0.23	0.87	2.10
	Heavy casement section, projected	0.13	0.63	1.53
Ordinary wood or metal door	Hollow metal, vertically pivoted	0.50	2.40	4.00
	Well fitted, non-weatherstripped	0.90	1.80	4.20
	Same, weatherstripped	0.45	0.90	2.10
Glass door	Poorly fitted, non-weatherstripped	0.90	3.70	8.40
Factory door	Same, weatherstripped	0.45	1.85	4.20
Metal-sash windows	Good installation	3.20	9.60	19.0
	1/8-in. crack	3.20	9.60	19.0
	Aluminum, double-hung or sliding, weatherstripped	0.10	0.53	1.27

Abstracted from Carrier Air Conditioning Co., *Handbook of Air Conditioning System Design*, McGraw-Hill Book Company, New York, 1966.

TABLE 8-15 Infiltration Due to Door Openings

Application	Cfm per Person entering Room per Door		
	72-in. Revolving Door	36-in. Swinging Door	
		No Vestibule	With Vestibule
Bank	6.5	8.0	6.0
Barber shop	4.0	5.0	3.8
Candy and ice cream	5.5	7.0	5.3
Cigar store	20.0	30.0	22.5
Department store (small)	6.5	8.0	6.0
Dress shop	2.0	2.5	1.9
Drug store	5.5	7.0	5.3
Hospital room		3.5	2.6
Lunch room	4.0	5.0	3.8
Men's shop	2.7	3.7	2.8
Restaurant	2.0	2.5	1.9
Shoe store	2.7	3.5	2.6

Abstracted from Carrier Air Conditioning Co., *Handbook of Air Conditioning System Design*, McGraw-Hill Book Company, New York, 1966.

TABLE 8-16 Rates of Heat Gain from Occupants of Conditioned Spaces; Based on 78°F Room DB Temperature

Degree of Activity	Typical Application	Total Heat Adults, Male, Btu/hr	Total Heat, Adjusted, Btu/hr	Sensible Heat, Btu/hr	Latent Heat, Btu/hr
Seated, at rest	Theater	400	350	210	140
Seated, very light work	Offices, hotels, apartments	480	420	230	190
Moderately active office work	Offices, hotels, apartments	640	510	255	235
Standing, light work or walking slowly	Department store, retail store, dime store	800	640	315	325
Light bench work	Factory	880	780	345	435
Moderate dancing	Dance hall	1360	1280	405	875
Walking 3 mi/hr or moderate work	Factory	1040	1000	350	650
Bowling	Bowling alley	1200	960	345	615
Heavy work, vigorous sports	Factory, gymnasium	2000	1800	635	1165

Notes:

* Adjusted total heat gain is based on normal percentage of men, women, and children for the application listed with the postulate that the gain from an adult female is 85 percent of that for an adult male, and that the gain from a child is 75 percent of that for an adult male.

* Adjusted total heat value for sedentary work, includes 60 Btu/hr for food per individual (30 Btu sensible and 30 Btu latent).

Source: ASHRAE, *Cooling and Heating Load Calculation Manual*, New York, 1979.

TABLE 8-17 Recommended Rate of Heat Gain from Selected Cooking Appliances Located in the Air-Conditioned Space

Appliance	Capacity	Overall Dimensions, in. (Width × Depth × Height)	Miscellaneous Data	Rated Watts	Recommended Rate of Heat Gain, Btu/hr		
					Without Hood		
					Sensible	Latent	Total
GAS-BURNING, COUNTER TYPE							
Coffee brewer per burner			With warm position	1750	750	2500	500
Coffee urn	5 gal	14-in dia.		5250	2250	7500	1500
Deep fat fryer	15 lb fat	14 × 21 × 15		7500	7500	15000	3000
Dry food warmer per ft ² of top				560	140	700	140
Griddle, frying per ft ² of top				4900	2600	7500	1500
Short order stove per burner			Open grates	3200	1800	5000	1000
ELECTRIC, COUNTER TYPE							
Coffee brewer per burner				625	770	1000	340
Coffee urn, electric	5 gal	18 × 20 × 13	2 heating units	3000	3850	1250	5100
Hotplate				5200	5300	3600	8900
Toaster, continuous	720 slices/hr	20 × 15 × 28	4 slices wide	3000	2700	2400	5100

ASHRAE Cooling and Heating Load Calculation Manual, New York, 1979.

TABLE 8-18 Rate of Heat Gain from Miscellaneous Appliances

Appliance	Miscellaneous Data	Manufacturer's Rating		Recommended Rate of Heat Gain, Btu/hr		
		W	Btu/hr	Sensible	Latent	Total
<i>Electrical Appliances</i>						
Hair drier	Blower type	1580	5,400	2,300	400	2,700
Hair drier	Helmet type	705	2,400	1,870	330	2,200
Sterilizer, instrument		1100	3,750	650	1200	1,850
Large copying machine	Operating		12,000	12,000	0	12,000
	Standby	6,000	6,000	0	0	6,000
<i>Gas-burning Appliances</i>						
Lab burners, Bunsen	1/16-in. barrel		3,000	1,680	420	2,100

ASHRAE Cooling and Heating Load Calculation Manual, New York, 1979.

TABLE 15—SOLAR HEAT GAIN THRU ORDINARY GLASS

0° NORTH LATITUDE														0° SOUTH LATITUDE							
Time of Year	Exposure	AM						SUN TIME						PM						Exposure	Time of Year
		6	7	8	9	10	11	1	2	3	4	5	6	7	8	9	10	11	12		
JUNE 21	North	0	45	65	74	78	80	82	80	78	74	65	45	0	South	DEC 22	JAN 21	&	NOV 21		
	Northeast	0	119	156	154	133	95	53	20	14	13	11	6	0	Southeast						
	East	0	116	147	125	91	43	14	14	14	13	11	5	0	East						
	Southeast	0	37	42	27	15	14	14	14	14	13	11	6	0	Northeast						
	South	0	6	11	13	14	14	14	14	14	13	11	6	0	North						
	Southwest	0	6	11	11	14	14	14	14	14	13	11	6	0	Northwest						
JULY 23	West	0	6	11	13	14	14	14	14	14	13	11	6	0	West	FEB 20	MAR 22	&	OCT 23		
	Northwest	0	6	11	13	14	20	53	95	133	154	156	119	0	Southwest						
	Horizontal	0	28	87	147	191	217	226	217	191	147	87	28	0	Horizontal						
	North	0	37	54	61	65	66	67	66	65	61	54	37	0	South						
	Northeast	0	118	153	150	124	86	43	16	14	13	11	6	0	Southeast						
	East	0	121	152	139	96	43	14	14	14	13	11	6	0	East						
& MAY 21	Southeast	0	46	52	36	18	14	14	14	14	13	11	6	0	Northeast	OCT 23	SEPT 22	&	JULY 23		
	South	0	6	11	13	14	14	14	14	14	13	11	6	0	North						
	Southwest	0	6	11	13	14	14	14	14	14	13	11	6	0	Northwest						
	West	0	6	11	13	14	14	14	14	14	13	11	6	0	West						
	Northwest	0	6	11	13	14	16	43	86	124	150	153	118	0	Southwest						
	Horizontal	0	29	91	151	195	223	233	223	195	151	91	29	0	Horizontal						
AUG 24	North	0	17	28	31	33	34	34	34	33	31	28	17	0	South	APR 20	MAY 22	&	SEPT 22		
	Northeast	0	110	141	133	102	61	24	14	14	13	12	6	0	Southeast						
	East	0	129	163	148	103	46	14	14	14	13	12	6	0	East						
	Southeast	0	67	79	65	35	151	14	14	14	13	12	6	0	Northeast						
	South	0	6	12	12	14	14	14	14	14	13	12	6	0	North						
	Southwest	0	5	12	13	14	14	14	14	15	13	12	6	0	Northwest						
APR 20	West	0	6	12	13	14	14	14	14	14	13	12	6	0	West	OCT 23	SEPT 22	&	JULY 23		
	Northwest	0	6	12	13	14	14	24	61	102	133	141	110	0	Southwest						
	Horizontal	0	31	97	150	206	241	245	234	206	150	97	31	0	Horizontal						
	North	0	6	12	13	14	14	14	14	14	13	12	6	0	South						
	Northeast	0	95	118	101	68	31	14	14	14	13	12	6	0	Southeast						
	East	0	124	167	151	107	47	14	14	14	13	12	6	0	East						
& MAR 22	Southeast	0	95	118	101	68	31	14	14	14	13	12	6	0	Northeast	APR 20	MAY 22	&	JULY 23		
	South	0	6	12	13	14	14	14	14	14	13	12	6	0	North						
	Southwest	0	6	12	13	14	14	14	21	68	101	118	95	0	Northwest						
	West	0	6	12	13	14	14	14	47	107	151	167	134	0	West						
	Northwest	0	6	12	13	14	14	14	31	68	101	118	95	0	Southwest						
	Horizontal	0	32	100	163	210	240	250	240	210	163	100	32	0	Horizontal						
OCT 23	North	0	6	12	13	14	14	14	14	14	13	12	6	0	South	APR 20	MAY 22	&	JULY 23		
	Northeast	0	67	79	65	35	15	14	14	14	13	12	6	0	Southeast						
	East	0	129	163	148	103	46	14	14	14	13	12	6	0	East						
	Southeast	0	110	141	133	102	61	24	14	14	13	12	6	0	Northeast						
	South	0	17	28	31	33	34	34	34	33	31	28	17	0	North						
	Southwest	0	5	12	13	14	14	24	61	102	133	141	110	0	Northwest						
FEB 20	West	0	6	12	13	14	14	14	46	103	148	163	129	0	West	APR 20	MAY 22	&	JULY 23		
	Northwest	0	6	12	13	14	14	14	15	35	65	79	67	0	Southwest						
	Horizontal	0	31	97	150	206	234	245	234	206	150	97	31	0	Horizontal						
	North	0	6	11	13	14	14	14	14	14	13	11	6	0	South						
	Northeast	0	46	52	36	18	14	14	14	14	13	11	6	0	Southeast						
	East	0	121	152	139	96	43	14	14	14	13	11	6	0	East						
NOV 21	Southeast	0	118	153	150	124	86	43	16	14	13	11	6	0	Northeast	MAY 22	&	JULY 23			
	South	0	37	54	61	65	66	67	66	65	61	54	37	0	North						
	Southwest	0	6	11	13	14	16	43	86	124	150	153	118	0	Northwest						
	West	0	6	11	13	14	14	14	43	96	139	152	121	0	West						
	Northwest	0	6	11	13	14	14	14	15	38	62	52	46	0	Southwest						
	Horizontal	0	29	91	151	195	223	233	223	195	151	91	29	0	Horizontal						
DEC 22	North	0	6	11	13	14	14	14	14	14	13	11	6	0	South	JUNE 21	&	JULY 23			
	Northeast	0	37	42	27	15	14	14	14	14	13	11	6	0	Southeast						
	East	0	116	147	135	93	43	14	14	14	13	11	6	0	East						
	Southeast	0	119	156	154	133	95	53	20	14	13	11	6	0	Northeast						
	South	0	45	65	74	78	80	82	80	78	74	65	45	0	North						
	Southwest	0	6	11	13	14	20	53	95	133	154	156	119	0	Northwest						
	West	0	6	11	13	14	14	14	43	93	135	147	116	0	West						
	Northwest	0	6	11	13	14	14	14	15	27	42	37	27	0	Southwest						
	Horizontal	0	28	87	147	191	217	226	217	191	147	87	28	0	Horizontal						
	Steel Sash, or No Sash	X 1.85 or 1.17	Haze: -15% (Max.)						Altitude: +0.7% per 1000 Ft						Dewpoint Decrease From 67 F + 7% per 10 F		Dewpoint Increase From 67 F - 7% per 10 F		South Lat. Dec. or Jan. + 7%		

Bold Face Values — Monthly Maximums Boxed Values — Yearly Maximums

TABLE 28—TRANSMISSION COEFFICIENT U—PITCHED ROOFS*
FOR HEAT FLOW DOWN—SUMMER. FOR HEAT FLOW UP—WINTER (See Equation at Bottom of Page)
Btu/(hr) (sq ft projected area) (deg F temp diff)

All numbers in parentheses indicate weight per sq ft. Total weight per sq ft is sum of component materials.

PITCHED ROOFS		CEILING										
		None	3/4" Wood Panel (2)	1/2" Gypsum Board (Plaster Board) (2)	Metal Lath Plastered		1/2" Gypsum or Wood Lath Plastered		Insulating Board Plain or 1/2" Sand Agg Plastered		Acoustical Tile on Furring or 3/4" Gypsum	
EXTERIOR SURFACE	SHEATHING				3/4" Sand Plaster (7)	3/4" Lt Wt Plaster (3)	1/2" Sand Plaster (5)	1/2" Lt Wt Plaster (2)	1/2" Board (2)	1" Board (4)	1/2" Tile (2)	3/4" Tile (3)
Asphalt Shingles. (2)	Bldg paper on 3/4" plywood (2)	.51	.27	.30	.32	.29	.29	.28	.22	.17	.23	.21
	Bldg paper on 2 1/2" wood sheathing (3)	.30	.23	.26	.27	.25	.25	.24	.20	.16	.21	.19
Asbestos-Cement Shingles (3) or Asphalt Roll Roofing (1)	Bldg paper on 3/4" plywood (2)	.59	.28	.34	.37	.33	.33	.31	.25	.18	.25	.22
	Bldg paper on 2 1/2" wood sheathing (3)	.45	.25	.29	.31	.28	.28	.27	.22	.17	.22	.20
Slates (8) Tile (10) or Sheet Metal (1)	Bldg paper on 3/4" plywood (2)	.64	.29	.36	.38	.34	.35	.47	.26	.19	.26	.23
	Bldg paper on 2 1/2" wood sheathing (3)	.48	.25	.29	.31	.28	.28	.27	.22	.17	.23	.20
Wood Shingles (2)	Bldg paper on 1" x 4" strips (7)	.53	.26	.31	.33	.30	.30	.28	.23	.17	.24	.21
	Bldg paper on 3/4" plywood (2)	.41	.23	.27	.29	.26	.27	.25	.21	.16	.21	.19
	Bldg paper on 2 1/2" wood sheathing (3)	.34	.21	.24	.25	.23	.23	.22	.19	.15	.19	.17

1958 ASHAE Guide

Equations: Summer (Heat Flow Down) Heat Gain, Btu/hr = (horizontal projected area, sq ft) × (U value) × (equivalent temp diff, Table 20).

TABLE 18-2 Recommended NC (Noise Criteria) for Selection of Diffusers and Various Applications

NC Curve	Recommended Noise Criteria (dB Attenuation)	
	Communication Environment	Typical Occupancy
Below NC 25	Extremely quiet environment. suppressed speech is quite audible, suitable for acute pickup of all sounds. Recording and performing studios require NC levels below 20	Broadcasting studios, concert halls, music rooms, church sanctuaries
NC 30	Very quiet office, suitable for large conferences, telephone use satisfactory. Levels below NC 30 are considered "very quiet"	Residences, theaters, libraries, executive offices, directors' rooms
NC 35	Quiet office; satisfactory for conference at a 15-ft table; normal voice 10-30 ft; telephone use satisfactory	Private offices, schools, hotel rooms, court rooms, hospital rooms
NC 40	Satisfactory for conferences at a 6-8-ft table; normal voice 6-12 ft; telephone use occasionally difficult	General offices, labs, dining rooms, building lobbies
NC 45	Satisfactory for conferences at a 4-5-ft table; normal voice 3-6 ft; raised voice 6-12 ft; telephone use occasionally difficult	Retail stores, cafeterias, corridors, large drafting & engineering offices, noisy reception areas
Above NC 50	Unsatisfactory for conferences of more than two or three persons; normal voice 1-2 ft; raised voice 3-6 ft; telephone use often difficult. Levels above NC 50 are considered "noisy"	Noisy offices, stenographic pools, print machine rooms, process areas, manufacturing

Source: Tuttie and Bailey Manufacturing Company.

TABLE 18-5. Selection and Performance Data for Round Ceiling Diffusers
(a Portion of a Manufacturer's Table with NC Numbers Added)

Size, in.;	Neck Area, ft ²	Neck Vel., fpm	700	800	900	1000	1100	1200	1300	1400	1600	1800	2000
5 0.136	CFM	95	110	120	135	150	165	175	190	220	245	270	
	SP	0.07	0.09	0.12	0.15	0.18	0.21	0.25	0.29	0.37	0.47	0.58	
	RAD	3-5	3-5	3-5	3-6	3-6	3-7	4-7	4-8	5-10	6-12	7-14	
	NC	18	22	25	28	31	34	36	37	41	44	46	
6	CFM	135	155	175	195	215	235	255	275	315	355	390	
	SP	0.07	0.09	0.11	0.14	0.16	0.2	0.24	0.27	0.36	0.45	0.56	
	RAD	3-5	3-6	3-6	3-7	4-7	4-8	4-9	5-10	6-12	6-14	7-15	
	NC	18	22	26	29	31	34	36	37	41	44	46	
8 0.349	CFM	245	280	315	350	385	420	455	490	560	630	700	
	SP	0.06	0.08	0.1	0.13	0.16	0.19	0.22	0.25	0.33	0.42	0.52	
	RAD	4-7	4-8	4-9	5-10	5-11	5-12	6-12	6-13	7-15	9-18	10-20	
	NC	19	23	29	30	33	35	37	39	43	46	49	
10 0.545	CFM	380	435	490	545	600	655	710	765	870	980	1090	
	SP	0.05	0.07	0.09	0.11	0.13	0.16	0.19	0.22	0.28	0.36	0.44	
	RAD	5-11	6-12	6-13	7-14	7-15	8-15	8-17	8-18	10-20	11-22	13-26	
	NC	21	25	29	32	34	37	39	41	44	48	51	
12 0.785	CFM	550	630	705	785	865	940	1020	1100	1260	1410	1570	
	SP	0.05	0.06	0.08	0.1	0.12	0.14	0.17	0.19	0.25	0.32	0.39	
	RAD	7-14	7-15	8-16	8-17	9-18	9-19	13-20	10-21	12-25	13-27	15-30	
	NC	23	26	30	33	36	38	41	43	47	50	53	
15 1.227	CFM	860	980	1100	1230	1350	1470	1600	1720	1960	2210	2450	
	SP	0.04	0.05	0.06	0.08	0.09	0.11	0.13	0.15	0.19	0.24	0.3	
	RAD	8-17	9-18	9-19	10-21	11-22	12-24	13-26	13-27	15-30	17-35	18-39	
	NC	24	28	32	35	38	40	41	43	48	51	54	
18 1.767	CFM	1240	1410	1590	1770	1940	2120	2300	2470	2830	3180	3530	
	SP	0.03	0.04	0.05	0.06	0.08	0.09	0.11	0.12	0.16	0.2	0.25	
	RAD	11-22	12-25	13-26	14-28	15-30	15-32	16-33	17-34	19-38	21-43	23-46	
	NC	26	30	32	35	38	41	43	45	49	52	54	
21 2.405	CFM	1680	1920	2160	2400	2650	2890	3130	3370	3850	4330	4810	
	SP	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09	0.12	0.15	0.19	
	RAD	12-24	14-28	15-30	16-32	17-34	18-36	19-38	20-40	22-44	24-48	27-55	
	NC	27	30	34	37	40	43	45	46	50	54	57	
24 3.142	CFM	2200	2510	2830	3140	3460	3770	4080	4400	5030	5660	6280	
	SP	0.04	0.06	0.07	0.09	0.1	0.12	0.15	0.17	0.22	0.28	0.35	
	RAD	15-30	16-33	17-35	18-37	19-38	20-40	21-42	23-45	25-51	28-57	31-63	
	NC	28	32	35	38	40	43	45	47	51	55	58	

Source: Anemostat Products Division, Dynamics Corporation of America